

SACHIN G. BADWAIK

DFSET, DIS & DIPLOMA IN (FIRE SERVICE ENGG.)

Rajendra Nagar, Balaghat Road,
TUMSAR, Dist.: Bhandara - 441912

E-Mail ID : sgbadwaik@gmail.com

Mob. No. : 09850318191, 09420866771.



GST No. : 27ANVPB778K121

SAMIKSHA ENTERPRIZES

FIRE & SAFETY EQUIPMENTS SUPPLIERS & MAINTENANCE

GANJ AKHADA COMPLEX, RAMKRISHNA NAGAR, TUMSAR
DIST. : BHANDARA (MH.)

13/06/2023

Ref. No. SET/Rem/1570/2023-24

Date :

RENEWAL CERTIFICATE

This is to Certify that following Old Fire Extinguisher Equipment's Servicing, Refilling, Maintains, Tested & Checked by me or in presence of me found working order on Good Condition.

Name of Party :- M/S. PRINCIPAL, SHIRINBAI NETERWALA SCHOOL
At – Maneck Nagar, Tumsar, Tah. –Tumsar, Distt. – Bhandara

Affiliation No. :- 1130005

Established Premises :- School Building

Sr. No.	Fire Extinguisher Equipment Type	Fire Extinguisher Equipment Capacity	Quantity In Nos.	Inspection & Servicing Date	Next Due Date For Servicing, Testing & Refilling	Remark
1	ABC [DCP]	04Kg.	06	13.06.2023	12.06.2024	
2	ABC [DCP]	05Kg.	04	13.06.2023	12.06.2024	
3	BC [DCP]	10Kg.	01	13.06.2023	12.06.2024	
4	BC [CO2]	05Kg.	01	13.06.2023	12.06.2024	
		Total	12			

Remark:-

- 1] This Certified One Year Valid Dt. 13.06.2023 To Dt. 12.06.2024
- 2] Emergency Call : Fire - 101, Ambulance – 108, Police - 100

[SAMIKSHA ENTRPRIZES]

SACHIN
GHANSHYA
M BADWAIK

Digitally signed by
SACHIN GHANSHYAM
BADWAIK
Date: 2023.06.13
12:04:42 +05'30'



FIRE EXTINGUISHER



FIRE DETECTOR



SAFETY HELMET



FIRE BUCKET



FIRE HOUSE PIPE



HOUSE REAL PIPE



FIRE SPRINKLER



FIRE BUZER



BRANCH PIPE NOZZLES



Municipal Council Tumsar
Dist. Bhandara (Maharashtra)



Phone-STD No.07183-Off.234679

mail : co.mc.tumsar@gmail.com

NPT/F.V./166./2023-24


Date:-15/06/2023

--: FIRE SAFETY CERTIFICATE :--

This is Certified that **M/s. Principal of Shirinbai Neterwala School, Maneck Nagar, Tumsar, Tah. Tumsar, District Bhandara** has installed Fire Extinguishers ABC (DCP) Raining Capacity of **4Kg. Nos. 06**, ABC (DCP) Raining Capacity of **5Kg. Nos. 04**, BC (DCP) of **10 Kg Capacity of 01 Numbers** and BC (Co₂) of **5 Kg Capacity of 01 Numbers** for the protection of the safety in school premises.

- 1) School has instructed to get all the fire safety equipments Inspected through Licensed agency in every six month i.e. January and July and get form B from Licensed agency. One copy of which has to be submitted mandatorily to the Municipal Council, Tumsar.
- 2) According to the Maharashtra Fire Prevention and Lifesaving Act 2006 it is mandatory to not install fire hydrant and sprinkar with alarm system.
- 3) Fire extinguishers equipments ABC (DCP) Raining Capacity of **4Kg. Nos. 06**, ABC (DCP) Raining Capacity of **5Kg. Nos. 04**, BC (DCP) of **10 Kg Capacity of 01 Numbers** and BC (Co₂) of **5 Kg Capacity of 01 Numbers** were Installed on **13/06/2023** and these are valid upto till **12/06/2024**.
- 4) It is also certified that Old Fire Extinguishers Equipments its Servicing, Refilling, Maintenance are in good conditions to run the school.




In-charge Fire Officer,
Municipal Council, Tumsar.